

## **Temporary Power Requirements**

- Minimum 100 amp capacity
- All 120 volt outlets must be GFCI protected
- Service conductors for 100 amp must be either 4-wire 1/0 AWG aluminum or 2 AWG copper or SOW cord
- On SOW, strip outer covering about 1 foot
- Cabinet must be weatherproof
- Provide a meter socket
- Minimum service conductor length is 10 feet
- Service conductor length is not limited